Water Audit Validation Certificate

Part A: Provided by Validator

Validator Provided

Audit Information:

Water Supplier Name: **City of Pomona** PWS ID: **1910126**

System Type: **Potable** Audit Period: **Calendar Year 2018**

Utility Representation: **Julie Carver, Steve Paz**

Validation Date: **09/24/2019** Call Time: **8:00am** Sufficient Supporting Documents Provided: **Yes**

Validation Findings& Confirmation Statements:

Key Audit Metrics:

Data Validity Score: **53** Data Validity Band (Level): **Level III (51-70)**

ILI: **.35** Real Loss: **236.16 acre-ft./yr.** Apparent Loss: **378.485 acre-ft./yr.**

Non-revenue water as percent of cost of operating system: **2.6 %**

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☑

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator: **Damian Martinez** Qualifications: **Water Audit Validator Certificate issued by the CA-NV Section of the AWWA**

Damian Martinez WAV

Water Audit Validation Certificate

Part B: Provided by Utility

Water Supplier Name: City of Pomona **Water Supplier ID Number: 1910126** **Water Audit Period: Calendar Year 2018**

Utility Provided

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

The City is looking into contracting with a company to perform meter testing and calibration on VOS production meters annually. The City recently awarded a contract to a meter manufacturer and going to systematically replace old large production meters in the next few years.

Certification Statement by Utility Executive:
This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, Water Audit and Loss Control Programs, Manual 36, Fourth Edition and in the Free Water Audit Software Version 5.

Executive Name (Print)	Executive Position	Signature	Date
Darron Poulsen	Water Resources Director	Darron Poulsen	10-1-19

Damian Martinez WATV