Certified Water Audit Level 1 Validation Document

Validator Provided

Audit Information:

Water Supplier Name: **City of Redlands – Water System**

PWS ID: **CA 3610037**

System Type: **Potable**

Audit Period: **Calendar Year 2017**

Utility Representation: **Cecilia Griego**

Validation Date: **06/17/2019** Interview Time: **1230hrs - 1430hrs** Sufficient Supporting Documents Provided: **YES**

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: **53** Data Validity Band (Level): **Band III (51-70)**

ILI: **2.33** Real Loss: **50.43 (gal/conn/day)** Apparent Loss: **14.89 (gal/conn/day)**

Non-revenue water as percent of cost of operating system: **21.2%**

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.
YES

Validator Information:

Water Audit Validator: **Steve Dennis**

Validator Qualifications: **Water Audit Validator Certificate issued by the CA-NV Section of the AWWA**

M.E. SIMPSON Co., Inc.