Certified Validation Report Template, Part A: Provided by Validator

Validator Provided

Audit Information:

Water System Name: Brawley

Public Water System Identification (PWSID)[1]: CA 1310001

[1]List only 1 PWSID, which should match the PWSID on the FWAS Instructions Tab. For Special cases where multiple water systems are connected with permanent two-way interties, list those additional PWSIDs in the **Notes** below and describe the water distribution system(s) configuration.

PWSID and Water System Configuration Notes (Provided to Validator by Water System):

Audit Period: Calendar 2020

Validation Date: 9/3/2020

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 63 Data Validity Band (Level): Band III (51-70)

ILI: 8.9 Real Loss: 102.39 (gal/conn/day) Apparent Loss: 19.77 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 3.7%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. X

Validator Information:

Water Audit Validator: Larry Lewison, Will Jernigan Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Certified Validation Report Template, Part A: Provided by Validator

Audit Information:

Validator Provided

Water System Name: Brawley

Public Water System Identification (PWSID)[1]: CA 1310001

[1]List only 1 PWSID, which should match the PWSID on the FWAS Instructions Tab. For Special cases where multiple water systems are connected with permanent two-way interties, list those additional PWSIDs in the **Notes** below and describe the water distribution system(s) configuration.

PWSID and Water System Configuration Notes (Provided to Validator by Water System):

Audit Period: Calendar 2020

Validation Date: 9/3/2020

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 63 Data Validity Band (Level): Band III (51-70)

ILI: 8.9 Real Loss: 102.39 (gal/conn/day) Apparent Loss: 19.77 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 3.7%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. X

Validator Information:

Water Audit Validator: Larry Lewison, Will Jernigan Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Certified Validation Report Template, Part B: Provided by Utility

Utility Provided

Water System Name: City of Brawley

Public Water System Identification (PWSID)[2]: CA 1310001

[2]List only 1 PWSID, which should match the PWSID on the FWAS Instructions Tab. For Special cases where multiple water systems are connected with permanent two-way interties, those additional PWSIDs should have been listed in the Notes section on Page 1 by the Validator.

Water Audit & Water Loss Improvement Steps:

- Staff will continue to be train on water loss prevention and tracking.
- Staff will meter water when fire hydrant is exercised and/or flushed.
- Staff will continue replacing inaccurate and/or old meters.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)	Executive Position	Signature	Date
Jorge Valle Gonzalez	Water Treatment Plant Chief Operator	Jorge Valle	09/24/21