Validator Provided

Certified Validation Report

Audit Information:

Water Supplier Name: City of Sonoma PWS ID: 4910012

System Type: Potable Audit Period: Calendar year 2017

Utility Representation: Mike Brett

Validation Date: 8/16/18

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 67 Data Validity Band (Level): Band III (51-70)

ILI: 1.17 Real Loss: 17.90 (gal/conn/day) Apparent Loss: 5.76 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 1.9%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Gregory Plumb Qualifications: Certified California Water Audit Validator, CA-NV AWWA

Certified Validation Report

Utility Provided

Water Supplier Name: City of Sonoma **Water Supplier ID Number:** 4910012 **Water Audit Period:** Calendar year 2017

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)	Executive Position	Signature	Date
J. Colleen Ferguson	Public Works Director/ City Engineer	J. Colleen Ferguson	8/23/2018