CA-NV AWWA Water Loss Technical Assistance Program

Wave 4 Water Audit Level 1 Validation Document

Validator Provided

Audit Information:

Utility: Bear Valley Community Services District PWS ID: 1510038

System Type: Potable Audit Period: Calendar 2016

Utility Representation: Dawn Smith

Validation Date: 7/7/2017 Call Time: 12:30pm Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 36 Data Validity Band (Level): Band II (26-50)

ILI: 0.25 Real Loss: 191.65 (gal/mile-main/day) Apparent Loss: 2.49 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 1.3

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Will Jernigan Validator Qualifications: Contractor for CA-NV AWWA Water Loss TAP

Certified Validation Report

Utility Provided

Water Supplier Name: **Water Supplier ID Number:** **Water Audit Period:**

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)	Executive Position	Signature	Date
Dawn Smith	Public Works Admin		8/30/18

Please note: This form is for use as a general reference for required reporting elements. The use of this form is not required for submitting validated water loss audits.