Level 1 Validation – Water Supplier Confirmation

This document confirms participation in, and endorsement of the Level 1 Validation as completed.

This acknowledgement is required for submission – alongside your Level 1 validated water audit software file – to the California Department of Water Resources.

Water Supplier Name:	City of Folsom
Water Supplier Public Water System ID:	341014
Water Audit Period:	Calendar 2018

Water Audit & Water Loss Improvement Steps

Steps taken in the audit period timeframe to increase data source accuracy, reduce real losses, and/or reduce apparent losses, as informed by the water audit.

- Proactive Leak Detection performed by Utility Maintenance Division
- **Offer water conservation rebates such as irrigation efficiency upgrades and high efficiency toilet rebates**
- **Continued to improve the reliability/accuracy of the City's fixed newtwork meter database**

Certification Statement by Water Supplier Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (print):	Marcus Yasutake, PE
Executive Position:	Environmental & Water Resources Director
Signature:	
Date	09/19/19

Level 1 Validation Certificate

WSO

This document verifies that the Level 1 Validation process was completed. The session details and audit review outcomes are included here.

This certificate is required for submission – alongside the Level 1 validated water audit software file – to the California Department of Water Resources.

Call Date: 9/13/2019

Water Supplier

Supplier Name: City of Folsom

Utility Participants: Vaughn Fleischbein (Engineering), Jeremy Shykowski (Water Distribution Supervisor), Nathan Stites (Engineering), Jim Kime (Water Treatment Plant Supervisor)

Validator

Validator:	Kris Williams, Water Systems Optimization
Validator Qualifications:	Water Audit Validator Certificate from the AWWA California Nevada Section

Key Audit Metrics

Data Validity Score:	66	
ILI:	5.68	
Real Loss:	90.83	gal / conn / day
Apparent Loss:	24.06	gal / conn / day
Non-Revenue Water as Percent of Cost of Operating System:	3.4%	

Certification Statement by Validator

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒