Level 1 Validation Certificate

This document verifies that the Level 1 Validation process was completed. The session details and audit review outcomes are included here.

This certificate is required for submission – alongside the Level 1 validated water audit software file – to the California Department of Water Resources.

Call Date: 6/5/2019

Water Supplier

Supplier Name:
City of Pico Rivera

Supplier Participants:
Adrian Rodriguez

Validator

Validator: Kevin Burgers,
Water Systems Optimization

Validator Qualifications: Water Audit Validator Certificate from the AWWA California Nevada Section

Key Audit Metrics

Data Validity Score: 71		
ILI: 0.17		
Real Loss: 2.39		gal / conn / day
Apparent Loss: 6.32		gal / conn / day
Non-Revenue Water as Percent of Cost of Operating System:	0.6%	

Certification Statement by Validator

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Level 1 Validation – Water Supplier Confirmation

This document confirms participation in and endorsement of the Level 1 Validation as completed.

This acknowledgement is required for submission – alongside your Level 1 validated water audit software file – to the California Department of Water Resources.

Water Supplier Name:	City of Pico Rivera
Water Supplier Public Water System ID:	1910042
Water Audit Period:	2017/2018

Water Audit & Water Loss Improvement Steps

Steps taken in the audit period timeframe to increase data source accuracy, reduce real losses, and/or reduce apparent losses, as informed by the water audit.

Meter Replacements and leak prevention monitoring

Certification Statement by Water Supplier Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (print):	Monica Heredia
Executive Position:	Deputy Director Public Works (City Engineer)
Signature:	MHeredia
Date	Click or tap here to enter text. 6/19/19