Validator Provided

Certified Water Audit Level 1 Validation Report

Audit Information:

Water Supplier Name: Valley of the Moon Water District

PWS ID: 4910013

System Type: Potable

Audit Period: Calendar year 2019

Utility Representation: Amanda Hudson, Dominic Ortega

Validation Date: 9/8/2020

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 75

Data Validity Band (Level): Band IV (71-90)

ILI: 0.79

Real Loss: 11.37 (gal/conn/day)

Apparent Loss: 7.35 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 7.6%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator: Gregory Plumb

Qualifications: Certified California Water Audit Validator, CA-NV AWWA

Certified Validation Report

Utility Provided

Water Supplier Name: Valley of the Moon Water District **Water Supplier ID Number:** 4910013 **Water Audit Period:** Calendar year 2019

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)	Executive Position	Signature	Date
Matt Fullner	IGM		10-2-20