Water Audit Level 1Validation- Validator Review & Certification Statement

Validator Provided

Water System(s) This Audit Covers:

Public Water System Identification (PWSID)[1]: CA 3310051 **Water System Name** Myoma Dunes Mutual Water Company

[1]*List only 1 PWSID which should match the PWSID on the FWAS Instructions Tab. For Special cases where the audit covers multiple water systems connected with permanent two-way interties, list those additional PWSIDs in the **Notes** below and describe the water distribution system(s) configuration.*

Notes (Provided to Validator by Water System):

Audit Period:

Validation Date: 10/20/2021

Water System Representatives: Audrey Dean

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement: I certify this meets the requirements of 23 CCR 638.5 (b)(4)(A-C).

Key Audit Metrics:

Data Validity Score: 70 **Data Validity Band (Level):** Band III (51-70) **ILI** 5.56

Real Loss: 99.41 (gal/conn/day)

Apparent Loss: 44.41 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 5.5

Cerification Statement by Validator:
This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☑

If not, rejected recommendations are included here:

Validator Information:

Water Audit Validator: Larry L., Will Jernigan **Validator Qualifications:** Water Audit Validator Certificate issued by the CA-NV Section of the AWWA