Level 1 Validation Certificate

WSO

This document verifies that the Level 1 Validation process was completed. The session details and audit review outcomes are included here.

This certificate is required for submission – alongside the Level 1 validated water audit software file – to the California Department of Water Resources.

Call Date: 6/23/2020

Water Supplier

Supplier Name:	Tuolumne Utilities District – Sonora/Jamestown System
Supplier Participants:	Glen Nunnelley, Matt Nolte

Key Audit Metrics

Data Validity Score:	68	
ILI:	1.74	
Real Loss:	46.62	gal / conn / day
Apparent Loss:	3.48	gal / conn / day
Non-Revenue Water as Percent of Cost of Operating System:	1.1%	

Validator

Validator:	Colin Stief Water Systems Optimization
Validator Qualifications:	Water Audit Validator Certificate from the AWWA California Nevada Section

Certification Statement by Validator

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Level 1 Validation – Water Supplier Confirmation

This document confirms participation in and endorsement of the Level 1 Validation as completed.

This acknowledgement is required for submission – alongside your Level 1 validated water audit software file – to the California Department of Water Resources.

Water Supplier Name:	Tuolumne Utilities District
Water Supplier Public Water System ID:	CA5510001
Water Audit Period:	CY 2019

Water Audit & Water Loss Improvement Steps

Steps taken in the audit period timeframe to increase data source accuracy, reduce real losses, and/or reduce apparent losses, as informed by the water audit.

Click or tap here to enter text.

Certification Statement by Water Supplier Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (print):	Erik Johnson
Executive Position:	District Engineer
Signature:	EJ
Date	7/17/20