Validator Provided

Certified Validation Report: Provided by Validator

Audit Information:

Water Supplier Name: **Ramona Municipal Water District** PWS ID: 3710019

System Type: **Potable** Audit Period: **Calendar 2019**

Utility Representation: **Joe Lomelli**

Validation Date: **September 9th, 2020** Meeting Time: **2 PM** Sufficient Supporting Documents Provided: **Yes**

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: **78** Data Validity Band (Level): **Band IV**

ILI: **0.21** Real Loss: **8.31 gallons/connection/day** Apparent Loss: **9.28 gallons/connection/day**

Non-revenue water as percent of cost of operating system: **3.8 %**

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator : **Tanmay Thakur** Qualifications: **Water Audit Validator Certificate issued by the CA-NV Section of the AWWA**

Certified Validation Report Template, Part B: Provided by Utility

Utility Provided

Water Supplier Name: **Water Supplier ID Number:** **Water Audit Period:**

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)	Executive Position	Signature	Date
D. MICHAEL HRETTS, PE.	DISTRICT ENGINEER		Sept. 22, 2020